

**TRANSFER CAPABILITY OF PUNJAB CONTROL AREA**

Sr. No.	Duration	Time Period (in hrs.)	Total Transfer Capability (TTC) of Pb. (MW) (a)	Reliability Margin (MW) (b)	Available Transfer Capability (ATC) of Pb. (MW) (c) = (a) - (b)	Long Term Access (LTA)/Medium Term Open Access (MTOA) (MW) (d)	ATC for Short-Term Open Access (STOA) (MW) (e) = (c)-(d)
1	Sep11 - April12	00-24	5000	300	4700	2850	1850
2	May12- Aug12	00-24	5400	300	5100	3000	2100
3	Dec12- Feb13	Peak hours	5100	300	4800	2800	2000
		Off-Peak hours	4800	300	4500	2800	1700
4	May13- July13	00-24	5600	300	5300	3350	1950
5	May14- July14	00-24	5700	300	5400	3790	1610
6	May15- Aug15	00-24	6200	500	5700	4033	1667
7	May16- Aug16	00-24	6400	500	5900	4102	1798
8	May17- June17	00-24	6500	600	5900	4261	1639
9	July17- Sept17	00-24	6700	600	6100	4261	1839
10	June18 - Sep18	00-24	7000	600	6400	4680	1720